



Utah Fuel Company

a subsidiary of The Coastal Corporation

P.O. Box 719 • Helper, Utah 84526 • (801) 637-7925


Salt Lake (801) 596-7111

March 20, 1990

0018

I, William W. Shriver, do certify that I have checked the sedimentation pond at the Railroad Loadout and that to the best of my professional knowledge and ability the pond:

1. Has been basically constructed and maintained as designed and in accordance with the approved plan and UMC 817.49(h).
2. Is monitored according to NPDES Permit No. UT-0023540.
3. The average depth of the pond, excluding sediment, is 5.71 feet. Overflow elevation is 7919.71 feet. The average maximum depth and elevation for the past year are 2.4 feet and 7914 feet, respectively.
4. The existing storage capacity is 56,910 cubic feet.
5. No fires have occurred in the construction material.
6. No hazardous conditions or instability of the dam or embankment have been detected.



SEAL

W^m W. Shriver

William W. Shriver

Registered Professional Engineer

Utah Registration No. 8632

REPLACES	!!	TEXT
Section 3.2 Page 3-17B	!!	Section 3.2 Page 3-17B Date 03/20/90!